

# Home Energy Rating Certificate

Projected Report  
Based on Plans

Rating Date:  
Registry ID:  
Ekotrope ID: dkgypobd

**A Closer  
LOOK**  
INSPECTION SERVICES  
Infrared Thermal Imaging

## HERS® Index Score:

# 63

Your home's HERS score is a relative performance score. The lower the number, the more energy efficient the home. To learn more, visit [www.hersindex.com](http://www.hersindex.com)

## Annual Savings

# \$1,020

\*Relative to an average U.S. home


**Home:**  
667 Elm Tree Ct  
Poolville, TX 76487

**Builder:**  
Jeff Hess

## Your Home's Estimated Energy Use:

	Use [MBtu]	Annual Cost
Heating	9.8	\$259
Cooling	7.2	\$189
Hot Water	9.3	\$244
Lights/Appliances	19.4	\$511
Service Charges		\$60
Generation (e.g. Solar)	0.0	\$0
<b>Total:</b>	<b>45.6</b>	<b>\$1,263</b>

**This home meets or exceeds the criteria of the following:**



## Home Feature Summary:

Home Type:	Single family detached
Model:	N/A
Community:	N/A
Conditioned Floor Area:	1,697 ft <sup>2</sup>
Number of Bedrooms:	4
Primary Heating System:	Air Source Heat Pump • Electric • 7.5 HSPF
Primary Cooling System:	Air Source Heat Pump • Electric • 14.3 SEER2
Primary Water Heating:	Residential Water Heater • Electric • 0.92 UEF
House Tightness:	6.2 ACH50
Ventilation:	55 CFM • 19.25 Watts (Default) • Exhaust Only
Duct Leakage to Outside:	Untested Forced Air
Above Grade Walls:	R-13
Ceiling:	Attic, R-38
Window Type:	U-Value: 0.29, SHGC: 0.22
Foundation Walls:	N/A
Framed Floor:	N/A

## Rating Completed by:

**Energy Rater:** Adrian Jourdan  
RESNET ID: 0311071

**Rating Company:** A Closer Look LLC  
3112 Ottawa Lane  
940891-3803

**Rating Provider:** RATERusa  
PO BOX 1280  
855-273-7872



*Adrian Jourdan*

Adrian Jourdan, Certified Energy Rater  
Digitally signed: 1/28/24 at 9:34 PM



Ekotrope RATER - Version:4.2.0.3325

The Energy Rating Disclosure for this home is available from the Approved Rating Provider.  
This report does not constitute any warranty or guarantee.